



DO NOT SCALE FROM THIS DRAWING.
 USE FIGURED DIMENSIONS IN ALL CASES.
 VERIFY DIMENSIONS ON SITE AND REPORT ANY DISCREPANCIES TO THE DESIGNERS IMMEDIATELY.
 THIS DRAWING TO BE READ IN CONJUNCTION WITH THE DESIGNERS SPECIFICATION.
 © THIS DRAWING IS COPYRIGHT AND MAY ONLY BE REPRODUCED WITH THE DESIGNERS PERMISSION.

- LEGEND**
- EXTERNAL LIGHTING**
- X1 LED EXTERIOR LUMINAIRE MOUNTED ON 5M COLUMN, 2700K, 12W, EXTRA LOW GLARE, CONTROLLED OPTICS
 - X2 LED PEDESTRIAN FOOTPATH LIGHT ON 5m COLUMN, 2700K, EXTRA LOW GLARE, CONTROLLED OPTICS
 - X3 LED EXTERIOR LUMINAIRE MOUNTED ON 5M COLUMN, 2700K, 20W, EXTRA LOW GLARE, CONTROLLED OPTICS

- LIGHTING CONTROLS NOTES**
- CARPARK AND ROADWAY LIGHTING (FITTINGS X1 AND X3) TO BE ON TIME AND DAYLIGHT CONTROLS TO TURN ON 30MINS BEFORE CARPARK OPENING AND 30 MINS AFTER CARPARK CLOSING CURRENTLY FORESEEN AS 6.30AM TO 10.30PM AND THEN ACTIVATE AS REQUIRED DEPENDING ON SUNLIGHT LEVELS.
 - PEDESTRIAN ACCESS ROUTE LIGHTING (FITTING X2) TO HAVE PHOTOCELL AND PRESENCE SENSOR CONTROLS - FITTINGS TO OPERATE ON PRESENCE CONTROLS BETWEEN 10.30PM AND 6.30 AM AND DAYLIGHT CONTROLS AS REQUIRED BETWEEN 6.30AM AND 10.30PM. PRESENCE CONTROLS TO BE LINKED BETWEEN FITTINGS TO LIGHT UP MULTIPLE FITTINGS ON ONE DETECTION.



LOW LEVEL GROUND LEVEL FEATURE LIGHTING TO BE INSTALLED FOR VIEWPOINT, INTEGRATED INTO STRUCTURE FOR LIMITED LIGHT SPILL TO SURROUNDINGS. DESIGN TO BE AGREED AT DETAILED DESIGN STAGE

P02	2024.09.24	PLANNING ISSUE	CK	CK
P01	2024.09.18	INITIAL COMMENT ISSUE	CK	CK
REV	DATE	DESCRIPTION	BY	APP

PROJECT: THE LONG POINT, LOUGHREA, CO GALWAY

TITLE: SITE LIGHTING LAYOUT

CLIENT: GALWAY COUNTY COUNCIL



DRAWN: CK	CHECKED: FF	APPROVED: DA
-----------	-------------	--------------

PROJECT NUMBER: 25141	DATE: 2024.09.17	SCALE @ A1: 1:500@A1
-----------------------	------------------	----------------------

STATUS DESCRIPTION: FOR REVIEW	STATUS: S3
--------------------------------	------------

DRAWING NUMBER: 25141 - MWP - 00 - 00 - DR - E - 9150	REV: P01
---	----------